

FIRE AND LIFE SAFETY INSPECTION NOTICE

Inspection Date: 7/15/10 Building Name: DOMS #10 CAAN: _____
 Department: Student Housing Rooms Inspected: All
 Safety Coordinator: Faye Perata Phone: 24347 Email: _____

NOTICE OF FIRE AND SAFETY HAZARDS: Our inspection of your building reveals the following fire and life safety items per the California Fire and Building Codes (2007 editions) and Title 19 of the California Code of Regulations. **PLEASE CORRECT:**

V = Violation noted C = Violation Corrected

| V | C | Violation | Code | V | C | Violation | Code |
|---|--------------------------|--|-------------------------------------|--|------------------------------|---|----------------------------------|
| 1. Exits | | | | 5. General Housekeeping/Storage | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | a) Door hardware must open door in single motion, without keys or special knowledge. Remove locks, bolts, etc. | CBC 1008.1.8 | <input type="checkbox"/> | <input type="checkbox"/> | a) Clean lint from clothes dryers | CFC 1107.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | b) Do not block exit doors, paths, aisles and corridors | T19 3.11 CBC 1021.2 | <input type="checkbox"/> | <input type="checkbox"/> | b) Move combustible objects away from heaters/appliances at least 3 feet | CFC 305.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | c) Fire rated doors must be automatic or self-closing and latching | CBC 715.4.7 | <input type="checkbox"/> | <input type="checkbox"/> | c) Portable heaters require tip over protection | UCDFD Fire Net T19 3.08 |
| <input type="checkbox"/> | <input type="checkbox"/> | d) All doors must open to 90 degrees | CBC1008.1.2 | <input type="checkbox"/> | <input type="checkbox"/> | d) Drapes, hangings, decorations must be treated with flame retardant chemicals | T19 3.19(f) |
| <input type="checkbox"/> | <input type="checkbox"/> | e) Provide/repair emergency lights/exit signs | CBC 1011.2 | <input type="checkbox"/> | <input type="checkbox"/> | e) Remove storage in electrical/mechanical rooms | T19 3.19(f) |
| 2. Fire Extinguishers and Cooking Appliances | | | | <input type="checkbox"/> | <input type="checkbox"/> | f) Maintain storage 24" below ceiling in non-sprinklered buildings | CFC 315.2.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | a) Service kitchen hood fire extinguishing system every six months | CFC 904.5.1 | <input type="checkbox"/> | <input type="checkbox"/> | g) Repair penetrations in fire rated walls, doors, etc. | NFPA 13 A.8.6.6 CBC 712.3.1.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | b) Commercial kitchens provided Class K extinguisher | CFC 904.11.5.2 | <input type="checkbox"/> | <input type="checkbox"/> | h) Remove combustible storage under stairs | CBC 1021.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | c) Clean grease filters over cooking appliance | CFC 904.11.6.4 | 6. Flammable/Combustible Liquids and/or Hazardous Materials | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | d) Do not obstruct extinguisher | T19 567 | <input type="checkbox"/> | <input type="checkbox"/> | a) Secure compressed gas cylinders | CFC 3003.5.3 |
| <input type="checkbox"/> | <input type="checkbox"/> | e) Fire extinguishers inspected monthly | CFC 906.6 | <input type="checkbox"/> | <input type="checkbox"/> | b) Use approved containers for flammable/combustible liquids | CFC 3404.4 NFPA 30 2003 |
| <input type="checkbox"/> | <input type="checkbox"/> | f) Mount fire extinguisher, top not more than 5 feet above floor | T19 567.6 CFC 906.9 | <input type="checkbox"/> | <input type="checkbox"/> | c) Use approved storage cabinet for flammable/combustible liquids | CFC 3404.3.2.1 |
| 3. Fire Sprinkler/Fire Alarm Systems | | | | <input type="checkbox"/> | <input type="checkbox"/> | d) Store oily rags U/L listed disposal container | T19 3.19(c) CFC 304.3.1 |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | a) Repair fire alarm device | CFC 907.20.1 | Additional Comments: _____ | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | b) Keep fire sprinklers/fire alarm equipment accessible. Remove obstructions | CFC 903.3.3 | <u>See Pg #2</u> | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | c) Provide spare sprinkler heads and wrench in box | CFC 907.3.1.10.6 NFPA 13 6.2.9.5 | <u>DOMS VACANT - REOPEN CERTIFICAT ON REPAIRS</u> | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | d) Fire sprinklers due for five-year service | CFC Table 901.6.1 | _____ A reasonable degree of fire safety exists at this time. | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | e) Reduce storage to 18" below sprinkler Exception: Shelving on walls | CFC 315.2.1 NFPA 13 6.2.7.2 | _____ You are hereby notified to correct said conditions immediately upon receipt of this notice. A re-inspection to determine if you have complied with this notice will be conducted on or after _____ | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | Replace missing escutcheon plates | | Thank you for your support of fire and life safety. | | | |
| 4. Electrical | | | | Received by: <u>Faye Perata</u> | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | a) Replace cover-plates for outlets/lights | CFC 605.6 | <input type="checkbox"/> | Second Inspection Date _____ | | |
| <input type="checkbox"/> | <input type="checkbox"/> | b) Electrical panels must have 36" clearance | CFC 605.3 | <input type="checkbox"/> | Third Inspection Date _____ | | |
| <input type="checkbox"/> | <input type="checkbox"/> | c) Remove extension cords or multi-plug adapters. Hardwire or use power taps | CFC 605.5 | Inspector: <u>[Signature]</u> | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | d) Remove surge protectors/extension cords through openings or attached in series | CFC 605.5 | Phone: 752-1236 | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | e) Electrical wiring, devices and appliances are in good condition and free of splicing and frayed cords | CFC 605.1 | Rev. 1/09 | | | |